



Katrina Koshivos <koshivosk@graffon-ma.gov>

4 Gloucester Road

1 message

Michael Killeen <killeenm@graffon-ma.gov>
To: Zoning Department <zba@graffon-ma.gov>

Wed, Sep 8, 2021 at 12:34 PM

Good afternoon,

The only comment from the fire department is that the smoke and carbon monoxide detectors must be brought up to code upon completion of the proposed addition. Thank you.

Respectfully,

Captain Michael Killeen
Fire Prevention Officer
Grafton Fire Department

RECEIVED

SEP 08 2021

Building Department

RECEIVED TOWN CLERK
GRAFTON, MA
2021 SEP -8 PM 1:02